



Mr. Danny Wong
Pure Direct (HK) Limited
Unit 6, 5/F Wah Sang Industrial Building,
Blk A, 14-18 Wong Chuk Yeung St, Fo Tan,
N. T.

30th May 2005

Dear Mr. Wong:

Below please find a certificate of analysis performed earlier based on the results of our water analysis of the water sample (spiked with known amount of bacteria and heavy metals) before and after passing through the pure cycle R.O. drinking water system (Pure Direct RO System) provided to us your company.

Certificate of Water Analysis


Contaminants Retained in Water after passage through the R.O. Water system - in ppm -

	<u>Total Bacteria</u>	<u>E. coli</u>	<u>Cadmium</u>	<u>Iron</u>	<u>Lead</u>
Initial water	1.4 x 10 ¹¹	1.8 x 10 ¹⁰	70	100	110
Sample 30 min	0	0	0.25%	3.6%	0.67%
Sample 60 min	0	0	0.24%	1.1%	0.90%

Thus, the results indicated that the RO water system is very efficient in removing 100% of microorganisms and >99% of input heavy metals, such as cadmium, and lead, and it is also efficient in removing 96% of the iron in the input water.

Please feel free to contact me for any query regarding the above shown results, thank you for your attention!




Peter Hoifu Yu, Ph.D
Associate Professor
Dept. of Applied Biology
& Chemical Technology